

## Clean up control panel cache

- 1) Unscrew Control Panel.
- 2) Unplug **the RJ 45 communication cable** from the panel and connect the control panel to the laptop.
- 3) Set up communication between your computer and the panel.
  - a. You must change IPv4: IP Address: 192.168.134.1 and sub-network mask: 255.255.255.0

Eth	ernet - vlastnosti X	Protokol IP verze 4 (TCP/IPv4) – vlastnosti
itě	Sdileni	Obecné
Připojit pomocí: 2 Realtek PCIe GbE Family Controller		Podporuje-li siť automatickou konfiguraci IP, je možné získat nastavení protokolu IP automaticky. V opačném případě vám správné nastavení
Toto	Konfigurovat	poradi správce sitě. O Získat IP adresu ze serveru DHCP automaticky
		IP adresa:     192.168.134.1       Maska podsítě:     255.255.0       Výghozí brána:     .
<	Protokol IP Verze 6 (ICP/IPV6) S	Ozigkat adresu serveru Divs automaticky OPoužít následující adresy serverů DNS:
N	ainstalovat Odinstalovat Vlastnosti	Upř <u>e</u> dnostňovaný server DNS:
Pop	ois otokol TCP/IP. Výchozí protokol pro rozlehlé sítě, který	Alternativní server DNS:
zajištuje komunikaci mezi propojenými sítěmi různého druhu.		Při ukončení ověřit platnost nastavení Upřesnjt
	OK Zrušit	OK Zrušit

- 4) Open an Internet browser.
- 5) In the search box, type http://192.168.134.178:8080/cgi-bin/setup\_about.cgi
- 6) Password: 2131
- 7) The Control Panel settings page opens for you.
- 8) On the left side, we select Update.
- 9) Select the .tgz file to clear the cache of the control panel and press SUBMIT.
- 10) Wait until you see Update was successful.
- 11) After that, you will have to log in again.
- 12) Again, select Update.
- 13) Select .tgz file with the latest version of the control panel and press SUBMIT.
- 14) Wait until we see Update was successful.
- 15) Unplug the communication cable from the control panel and plug back the cable from PLC.
- 16) Wait for all the files to update and that's it.